



PRINCE WILLIAM COUNTY
Department of Development Services – Building Development Division

ELECTRICAL & PLUMBING CERTIFICATION

Version 2009-08-11

| | |
|---|---|
| SITE ADDRESS _____ _____ JOB NAME _____ | MAP PAGE _____ GRID #: _____ |
|---|---|

| | | |
|---|--|--|
| MASTER ELECTRICIAN ELE PERMIT #: ELE20 ___ - ____ NAME: _____ (Type or Print) MASTER #: _____ ADDRESS: _____ _____ _____ CLASS ___ TEL # _____ | CONTRACTOR/BUILDER BLD PERMIT #: BLD20 ___ - ____ NAME: _____ (Type or Print) ADDRESS: _____ _____ _____ STATE REGISTRATION #: _____ _____ CLASS ___ TEL # _____ | MASTER PLUMBER PLB PERMIT # PLB20 ___ - ____ NAME: _____ (Type or Print) MASTER #: _____ ADDRESS: _____ _____ _____ CLASS ___ TEL # _____ |
|---|--|--|

THE FOLLOWING ELECTRICAL AND PLUMBING RELATED WORK WAS INSPECTED:

- | | |
|---|--|
| <input type="checkbox"/> In concrete floor decks prior to placement of concrete <input type="checkbox"/> In formed walls prior to placement of concrete <input type="checkbox"/> Post light ditch-specify depth _____ <input type="checkbox"/> Well ditch <input type="checkbox"/> Electrical circuit for systems furniture (For PWC and School Board only) <input type="checkbox"/> Water line replacement <input type="checkbox"/> In or below slabs-on-grade prior to placement of concrete | <input type="checkbox"/> Electrical work involving parking lot/site lighting ditches/trenches <input type="checkbox"/> Electrical sign <input type="checkbox"/> Sump pump / septic pump wiring <input type="checkbox"/> Well water line <input type="checkbox"/> Concrete encased grounding electrode: <input type="checkbox"/> Minimum 20 feet of ½ inch rebar <input type="checkbox"/> Minimum 20 feet of #4 copper conductor |
|---|--|

THE FOLLOWING HAVE BEEN VERIFIED:

- | | |
|--|---|
| <input type="checkbox"/> 160 PSI rated water supply piping <input type="checkbox"/> The approved Plans have been followed <input type="checkbox"/> All materials are approved for the purpose used <input type="checkbox"/> Bonding and workmanship of the conduit and conduit size are correct | <input type="checkbox"/> All concealed grounding has been properly placed and bonded <input type="checkbox"/> The connections are correct <input type="checkbox"/> The support and typing of the conduit is correct <input type="checkbox"/> Support for electrical boxes is correct |
|--|---|

GENERAL CONDITIONS:

DATE OF INSPECTION(S): _____ TIME OF INSPECTION(S): _____

A COPY OF THE REQUIRED ELECTRICAL AND PLUMBING PERMIT WAS POSTED ON THE CONTRUCTION SITE AT THE TIME OF THIS INSPECTION. I CERTIFY THAT THE INSTALLATION MEETS ALL REQUIREMENTS OF THE VIRGINIA UNIFORM STATEWIDE BUILDING CODE.

| | |
|--|---------------|
| _____ SIGNATURE OF MASTER ELECTRICIAN | _____ DATE |
| _____ SIGNATURE OF MASTER PLUMBER | _____ DATE |

| |
|---|
| <p align="center"><i>Staff Use Only</i></p> REMARKS: |
|---|